

**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From :
Station Fire Officer
Wanaparthy



To,
The Correspondent
UHODAYA B.Ed& D.Ed College
Srinivasapuram
Wanaparthy.

Rc.No. 128/52/2014, Dt: 08-04-2016.

Sub: T.G. State Disaster Response&Fire Services Department - C/R-II - Mahabubnagar District - Issue of No Objection Certificate for renewal to the Existing Educational Building of **UHODAYA B.Ed& D.Ed College of Engineers Educational Academy at SY.No 198 & 199 at Srinivasapuram(v) Wanaparthy(M) Mahabubnagar District.** - Reg.

- Ref:1. Section 13 (2) of A.P. Fire Services Act,1999 and Rule 15 (2) of A.P. Fire and Emergency Operations and Levy of Fee Rules,2006.
2. Chief Office Instructions Memo.Rc.No. of 2305/B2/2007 dt,28-2-2007 and 12-9-2008.
3. Lr. No.-Nil- Dt: 05-04-2016 of the Owner /Builder/Authorized representative of **UHODAYA B.Ed& D.Ed College of Engineers at Educational Academy at SY.No 198 & 199 at Srinivasapuram(v) Wanaparthy(M) Mahabubnagar District**
4. Circular Memo.Rc.No.2305/B2/2007 dt,30-12-2009 of the Director General of State Disaster Response & Fire Services Department, A.P. Hyderabad.
5.Chief office Circular Memo RC.No 4039-2/EODB/2015 Dated 03-06-2016
6. Inspection Report of Station Fire Officer Wanaparthy with Rc.No.4/SFO/WNP/ 2016, dt: 07-04-2016.

Vide reference 3rd cited, the Owner/Builder/Authorized representative has informed that he has been taken No Objection certificate for occupancy from this Department and requested to issue the No Objection Certificate for renewal in terms of G.O. reference 4th cited to the **UHODAYA B.Ed& D.Ed College of Engineers Educational Academy at SY.No 198 & 199 at Srinivasapuram(v) Wanaparthy(M) Mahabubnagar District.**

2. Vide reference 5th cited, the Station Fire Officer, Wanaparthy has inspected the building on Dt. 06-04-2016 and recommended for the issue of No Objection Certificate for renewal for the above Educational building

3. **Particulars of the Educational Building:-**
I. Height of the Building: **9.25 Meters.**
II. **Open Spaces.**

Direction	Required as per NBC	Provided	Deficit
East	6.00 Mtrs.	6.00 Mtrs.	-Nil-
West	6.00 Mtrs.	6.00 Mtrs.	-Nil-
North	6.00 Mtrs.	6.00 Mtrs.	-Nil-
South	6.00 Mtrs.	4.00 Mtrs.	2.00 Mtrs

III. Deficiencies in the Means of Escape

Sl. No.	Staircase	Required as per NBC-2005		Provided		Deficit
		No's	Width	No's	Width	
1	Internal	1	1.5 Mtrs.	1	1.50 Mtrs	Nil
2	External	1	1.5	1	1.00	Nil

IV. Floor wise particulars

:: 2 ::

S N	Floor	Floor Area in Sq. Meters	Occupancy	No. of Students & Staff members in the Floor.	Means of Escape as per required NBC-2005	Provided
1.	Ground Floor	780.00	Educational	100	1.50 Mtrs.	12.00 Mtrs.
2.	First Floor	780.00	Educational	50	1.50 Mtrs.	2.50 Mtrs.
2.	Second Floor	780.00	Educational	50	1.50 Mtrs.	2.50 Mtrs.
Total		2340.00	Educational	200	4.50 Mtrs.	15.00 Mtrs.

The management has remitted Fire precaution Fee Rs.10000/- (Rupees ten thousand only) vide Challan No.10672, dt:22-08-2015 at State Bank of Hyderabad Branch: Wanaparthy.

V. Fire Safety Measures:

Sl. No.	Fire Safety Measures	Required as per Table 23 of NBC of India 2005.	Provided	Deficiency
1.	2.	3.	4.	5.
1.	Fire Extinguishers	09 Nos.	09 Nos.	-Nil-
2.	Fire Buckets	12 Nos.	12 Nos.	-Nil-
3.	Hose Reel	03 Nos.	03 Nos.	-Nil-
4.	Terrace Tank 5,000 Ltrs.	01 No.	01 No.	-Nil-
5.	Booster Pump 450 LPM	01 No.	01 No.	-Nil-

4. The Fire Safety systems were tested by the committee members during the inspection and performance found satisfactory. Therefore, this office has No Objection for renewal clearanceto the existing Educational Building of the **UHODAYA B.Ed & D.Ed College of Engineers Educational Academy at SY.No 198 & 199 at Srinivasapuram(v) Wanaparthy(M)** Mahabubnagar District. subject to the following conditions.

- i. All the Fire protection arrangements shall be maintained in good condition as seen during inspection.
- ii. All the escape/exit routes shall not be kept locked/blocked or encroached.
- iii. All the occupants must know the correct method of operation of the Fire Fighting system installed.
- iv. Any loss of life or property due to non-functioning of Fire safety measures and other installations shall be the responsibility of the management.
- v. All students /Staff members of the institution shall be trained to operate the Fire safety equipments during emergency.
- vi. Addition/alteration, if any in the building may be obtained with prior permission from this Department.
- vii. Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

5. This No Objection for renewal is valid upto five years from the date Of issue and the management shall submit the application for renewal of No Objection Certificate three months before the due date of the renewal.


 Station Fire Officer 8-09-15
 Wanaparthy
 Station Fire Officer
 Fire Station Wanaparthy

Copy to the District Fire Officer, Mahabubnagar.
 Copy to the Station Fire Officer, Wanaparthy